

CERTIFICATE

Issued to:
Applicant:
Koncar Niskonaponske Sklopke I Prekidaci d.o.o.
Borongajska cesta 81b
10001 Zagreb, Croatia

Licensee:
Koncar Niskonaponske Sklopke I Prekidaci d.o.o.
Borongajska cesta 81b
10001 Zagreb, Croatia

Product : switch-disconnector
Trade name(s) : KONCAR
Type(s)/model(s) : CS 16, CS 25, CS 32 and CS 40R

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-3:2009, EN 60947-3:2009/A1:2012, EN 60947-3:2009/A1:2012/C1:2013 and EN 60947-3:2009/A2:2015
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 901295


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 19 March 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-107570

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



R Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	: switch-disconnector
Trade name(s)	: KONCAR
Type(s)/model(s)	: CS 16, CS 25, CS 32 and CS 40R
Number of poles	: 3 pole 3-pole + N
Rated insulation voltage (Ui)	: 690 Vac
Rated impulse withstand voltage	: 6 kV
Operational performance	: 6000 operating cycles
Wire size	: minimum 2,5 mm ² rigid/flexible maximum 6 mm ² flexible 10 mm ² rigid
Enclosure	: thermoplastic material 110 mm x 110 mm x 85 mm

Product data – type CS 16

Conventional enclosed thermal current (I _{the})	: 16 A
Rating/utilization category (Ue Ie)	: AC-3 AC-21A 220/230 V 13 A / 3,7 kW 380/400 V 11 A / 5,5 kW 16 A 660/690 V 9 A / 7,5 kW
Rated short-time withstand current (I _{cw})	: 400 A - 1 s
Rated short-circuit making capacity (I _{cm})	: 1000 A peak

Product data – type CS 25

Conventional enclosed thermal current (I _{the})	: 25 A
Rating/utilization category (Ue Ie)	: AC-3 AC-21A 220/230 V 19 A / 5,5 kW 380/400 V 15 A / 7,5 kW 25 A 660/690 V 13 A / 11 kW
Rated short-time withstand current (I _{cw})	: 500 A - 1 s
Rated short-circuit making capacity (I _{cm})	: 1200 A peak

Product data – type CS 32

Conventional enclosed thermal current (I _{the})	: 32 A
Rating/utilization category (Ue Ie)	: AC-3 AC-21A 220/230 V 27 A / 7,5 kW 380/400 V 22 A / 11 kW 32 A 660/690 V 17 A / 15 kW
Rated short-time withstand current (I _{cw})	: 600 A - 1 s
Rated short-circuit making capacity (I _{cm})	: 1400 A peak

Product data – type CS 40R

Conventional enclosed thermal current (I _{the})	:	40 A	
Rating/utilization category (U _e I _e)	:	AC-3	AC-21A
		220/230 V	27 A / 7,5 kW
		380/400 V	22 A / 11 kW
		660/690 V	17 A / 15 kW
Rated short-time withstand current (I _{cw})	:	600 A - 1 s	
Rated short-circuit making capacity (I _{cm})	:	1400 A peak	

TESTS**Test requirements**

EN 60947-3:2009
EN 60947-3:2009/A1:2012
EN 60947-3:2009/A1:2012/C1:2013
EN 60947-3:2009/A2:2015

Test result

The test results are laid down in DEKRA test file 223522200.

Additional information

This certificate replaces certificate No. 2126673.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

Koncar Niskonaponske Sklopke I Prekidaci d.o.o.
Borongajska cesta 81b
10001 Zagreb, Croatia